

Summary Report
For the
Tecumseh Distribution System
(260004969)
For the year
2021

Prepared for the Town of Tecumseh

By Brad Dupuis, C.Tech.
Manager Water Services, O.R.O.

Table of Contents

Section 1: Overview 3

Section 2: Non-Compliance Issues..... 4

Section 3: System Capability – 2021 Water Consumption 4

Section 1: Overview

This report has been prepared and submitted in accordance with Schedule 22 of O. Reg. 170/03 under the *Safe Drinking Water Act*. Schedule 22 requires:

The owner of a drinking-water system shall ensure that, not later than March 31 of each year after 2003, a report is prepared in accordance with subsections (1) and (2) for the preceding calendar year and is given to the members of the municipal council.

Schedule 22 also states that:

- 1) The report must:
 - a) list the requirements of the *Act*, the regulations, the system's approval and any order that the system failed to meet at any time during the period covered by the report and specify the duration of the failure; and
 - b) for each failure referred to in clause (a), describe the measures that were taken to correct the failure.
- 2) The report must also include the following information for the purpose of enabling the owner of the system to assess the capability of the system to meet existing and planned uses of the system. A summary of the quantities of the water supplied during the period covered by the report, including monthly flows.

In June 2003, the provincial *Safe Drinking Water Act* came into effect. The Drinking Water Systems Regulation (O.Reg. 170/03) defines how various drinking water systems are to be operated.

According to this Regulation, the Tecumseh Distribution System is classified as a Large Municipal Residential System (LMR).

Section 2: Non-Compliance Issues

During the year of 2021 there was zero (0) reportable issues.

Section 3: System Capability – 2021 Water Consumption

In accordance with the Agreement between the Town of Tecumseh and the City of Windsor for the provision of water services to the Town of Tecumseh, executed under By-Law No. 2004-71, the Maximum Daily Flow shall not exceed **87 Million Litres** (87 MLD) or 87,000 cubic meters.

The **Maximum Daily Flow** for 2021 was **15,046,000 Litres** (15,046 Cubic Meters) on August 25, 2021.

Monthly average and daily flows for 2021 are attached for reference.

A summary of the **monthly** total volume supplied by the City of Windsor to the Town of Tecumseh in the year 2021 is provided below:

Month	Total Volume (cubic meters)
January	205,955
February	187,871
March	205,166
April	213,026
May	290,750
June	330,063
July	300,502
August	390,294
September	386,885
October	281,487
November	246,455
December	230,764
Total	3,269,218



Monthly Report
Meter Chamber
Net Flow Totals

Town of Tecumseh
Water System
Reports

M_FlowTotal_Net_
03/02/2021 04:30:58 PM

Report Date From 01/01/2021 12:00:00 PM
To: 01/02/2021 12:00:00 PM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	661.0	398.0	1670.0	3062.0	0.0	-28.0	40.0	150.0	298.0	449.0	-298.0	N/A	6402.0
2	696.0	409.0	1663.0	3048.0	0.0	-40.0	28.0	181.0	318.0	465.0	-398.0	N/A	6370.0
3	649.0	392.0	1589.0	2972.0	0.0	-43.0	27.0	192.0	364.0	588.0	-121.0	N/A	6609.0
4	667.0	396.0	1580.0	2915.0	0.0	-49.0	20.0	164.0	341.0	566.0	-58.0	N/A	6542.0
5	653.0	389.0	1572.0	2923.0	0.0	-75.0	-4.0	186.0	359.0	583.0	-84.0	N/A	6502.0
6	656.0	398.0	1590.0	2959.0	0.0	-52.0	19.0	173.0	351.0	584.0	-48.0	N/A	6630.0
7	658.0	391.0	1592.0	2954.0	0.0	-45.0	25.0	162.0	340.0	551.0	-146.0	N/A	6482.0
8	727.0	422.0	1731.0	3177.0	0.0	-29.0	38.0	196.0	340.0	523.0	-320.0	N/A	6805.0
9	701.0	411.0	1716.0	3138.0	0.0	-33.0	40.0	192.0	335.0	507.0	-353.0	N/A	6654.0
10	656.0	390.0	1587.0	2974.0	0.0	-83.0	-7.0	153.0	345.0	576.0	-73.0	N/A	6518.0
11	664.0	390.0	1560.0	2918.0	0.0	-92.0	-19.0	158.0	375.0	633.0	-106.0	N/A	6481.0
12	677.0	400.0	1583.0	2963.0	0.0	-85.0	-15.0	161.0	371.0	627.0	-57.0	N/A	6625.0
13	638.0	374.0	1545.0	2906.0	0.0	-82.0	-2.0	168.0	367.0	620.0	-55.0	N/A	6479.0
14	638.0	381.0	1562.0	2915.0	0.0	-72.0	1.0	149.0	332.0	543.0	-72.0	N/A	6377.0
15	715.0	417.0	1723.0	3169.0	0.0	-22.0	46.0	176.0	328.0	495.0	-279.0	N/A	6768.0
16	659.0	386.0	1653.0	3078.0	0.0	-26.0	43.0	173.0	324.0	468.0	-385.0	N/A	6373.0
17	697.0	414.0	1616.0	3039.0	0.0	-75.0	3.0	149.0	355.0	575.0	-111.0	N/A	6662.0
18	614.0	366.0	1549.0	2950.0	0.0	-90.0	-19.0	112.0	378.0	615.0	-49.0	N/A	6426.0
19	645.0	380.0	1554.0	2979.0	0.0	-90.0	-14.0	186.0	415.0	605.0	-104.0	N/A	6556.0
20	714.0	430.0	1641.0	3115.0	0.0	-77.0	-4.0	172.0	360.0	600.0	-76.0	N/A	6875.0
21	829.0	502.0	1760.0	3263.0	0.0	-50.0	27.0	144.0	340.0	561.0	-56.0	N/A	7320.0
22	1365.0	893.0	2116.0	3693.0	0.0	24.0	84.0	135.0	307.0	459.0	-275.0	N/A	8801.0
23	638.0	381.0	1675.0	3110.0	0.0	-28.0	42.0	174.0	326.0	454.0	-405.0	N/A	6367.0
24	578.0	346.0	1564.0	2958.0	0.0	-71.0	2.0	171.0	370.0	606.0	5.0	N/A	6529.0
25	562.0	342.0	1543.0	2899.0	0.0	-81.0	-4.0	155.0	352.0	584.0	16.0	N/A	6368.0
26	638.0	383.0	1588.0	3002.0	0.0	-94.0	-20.0	132.0	361.0	598.0	20.0	N/A	6608.0
27	609.0	357.0	1561.0	2922.0	0.0	-86.0	-12.0	143.0	361.0	599.0	13.0	N/A	6467.0
28	606.0	358.0	1550.0	2927.0	0.0	-101.0	-27.0	178.0	343.0	554.0	8.0	N/A	6396.0
29	681.0	396.0	1732.0	3342.0	0.0	-63.0	5.0	230.0	379.0	572.0	-471.0	N/A	6803.0
30	683.0	409.0	1752.0	3363.0	0.0	-14.0	55.0	175.0	323.0	487.0	-357.0	N/A	6876.0
31	582.0	352.0	1554.0	2945.0	0.0	-101.0	-29.0	171.0	358.0	581.0	-129.0	N/A	6284.0
Monthly To...	21156.00	12653.00	50671.00	94578.00	0.00	-1853.00	369.00	5161.00	10816.00	17228.00	-4824.00	N/A	205955.00



Monthly Report
Meter Chamber
Net Flow Totals

Town of Tecumseh
Water System
Reports
M_FlowTotal_Net_MCx
15/03/2021 09:12:13 AM

Report Date From:01/02/2021 12:00:00 AM

To: 01/03/2021 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	582.0	352.0	1553.0	2945.0	0.0	-101.0	-28.0	169.0	358.0	580.0	-128.0	0.0	6282.0
2	605.0	362.0	1553.0	2941.0	0.0	-117.0	-37.0	210.0	398.0	648.0	-179.0	0.0	6384.0
3	586.0	351.0	1540.0	2949.0	0.0	-114.0	-43.0	218.0	419.0	691.0	-95.0	0.0	6502.0
4	604.0	366.0	1551.0	2943.0	0.0	-112.0	-39.0	220.0	413.0	677.0	-132.0	0.0	6491.0
5	588.0	350.0	1544.0	2916.0	0.0	-112.0	-42.0	203.0	399.0	649.0	-160.0	0.0	6335.0
6	653.0	386.0	1708.0	3189.0	0.0	-62.0	4.0	234.0	365.0	529.0	-515.0	0.0	6491.0
7	623.0	371.0	1709.0	3192.0	0.0	-62.0	9.0	224.0	372.0	537.0	-528.0	0.0	6447.0
8	621.0	373.0	1585.0	2994.0	0.0	-95.0	-19.0	233.0	420.0	687.0	-173.0	0.0	6626.0
9	630.0	377.0	1564.0	2991.0	0.0	-109.0	-39.0	235.0	435.0	703.0	-148.0	0.0	6639.0
10	635.0	374.0	1578.0	2986.0	0.0	-98.0	-28.0	225.0	416.0	681.0	-86.0	0.0	6683.0
11	634.0	387.0	1589.0	2990.0	0.0	-83.0	-10.0	227.0	421.0	698.0	-42.0	0.0	6811.0
12	601.0	364.0	1575.0	2969.0	0.0	-82.0	-12.0	243.0	426.0	709.0	-149.0	0.0	6644.0
13	628.0	367.0	1684.0	3125.0	0.0	-67.0	5.0	261.0	409.0	654.0	-310.0	0.0	6756.0
14	606.0	355.0	1635.0	3085.0	0.0	-64.0	7.0	246.0	407.0	634.0	-314.0	0.0	6597.0
15	605.0	355.0	1622.0	3059.0	0.0	-73.0	0.0	237.0	414.0	642.0	-351.0	0.0	6510.0
16	565.0	344.0	1546.0	2925.0	0.0	-94.0	-20.0	248.0	396.0	643.0	-130.0	0.0	6423.0
17	612.0	371.0	1587.0	2999.0	0.0	-77.0	-7.0	232.0	436.0	727.0	-23.0	0.0	6857.0
18	636.0	385.0	1582.0	2983.0	0.0	-88.0	-8.0	201.0	418.0	689.0	63.0	0.0	6861.0
19	629.0	382.0	1578.0	2978.0	0.0	-53.0	24.0	160.0	396.0	655.0	27.0	0.0	6776.0
20	673.0	388.0	1712.0	3185.0	0.0	-42.0	29.0	187.0	401.0	602.0	-98.0	0.0	7037.0
21	660.0	382.0	1717.0	3183.0	0.0	-45.0	26.0	200.0	405.0	594.0	-148.0	0.0	6974.0
22	651.0	394.0	1650.0	2794.0	0.0	-74.0	1.0	175.0	408.0	660.0	47.0	0.0	6706.0
23	630.0	381.0	1580.0	2974.0	0.0	-67.0	6.0	176.0	397.0	665.0	88.0	0.0	6830.0
24	1248.0	795.0	2822.0	601.0	0.0	-22.0	46.0	208.0	437.0	717.0	106.0	0.0	6958.0
25	1434.0	914.0	3125.0	133.0	0.0	-24.0	49.0	202.0	438.0	721.0	85.0	0.0	7077.0
26	1428.0	907.0	3085.0	128.0	0.0	-19.0	50.0	211.0	422.0	704.0	105.0	0.0	7021.0
27	1540.0	967.0	3330.0	112.0	0.0	-1.0	66.0	221.0	395.0	622.0	-82.0	0.0	7170.0
28	1501.0	942.0	3298.0	122.0	0.0	7.0	77.0	216.0	383.0	587.0	-150.0	0.0	6983.0
Monthly T...	21408.00	13042.00	52602.00	70391.00	0.00	-1950.00	67.00	6022.00	11404.00	18305.00	-3420.00	0.00	187871.00



Monthly Report
Meter Chamber
Net Flow Totals

Town of Tecumseh
Water System
Reports
M_FlowTotal_Net_MCx
01/04/2021 03:30:00 AM

Report Date From:01/03/2021 12:00:00 AM
To:01/04/2021 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1414.0	894.0	3037.0	123.0	0.0	-40.0	34.0	186.0	402.0	671.0	149.0	0.0	6870.0
2	1421.0	897.0	3034.0	118.0	0.0	-38.0	32.0	169.0	387.0	649.0	132.0	0.0	6801.0
3	1401.0	880.0	3020.0	118.0	0.0	-36.0	35.0	169.0	383.0	646.0	186.0	0.0	6802.0
4	1381.0	875.0	2987.0	119.0	0.0	-54.0	26.0	196.0	396.0	658.0	99.0	0.0	6683.0
5	1389.0	879.0	3006.0	109.0	0.0	-47.0	22.0	185.0	397.0	664.0	77.0	0.0	6681.0
6	1505.0	949.0	3303.0	120.0	0.0	9.0	74.0	199.0	374.0	578.0	-198.0	0.0	6913.0
7	1501.0	936.0	3296.0	123.0	0.0	-1.0	67.0	204.0	366.0	547.0	-285.0	0.0	6754.0
8	1406.0	890.0	3029.0	123.0	0.0	-32.0	35.0	172.0	395.0	664.0	87.0	0.0	6769.0
9	1388.0	876.0	2998.0	124.0	0.0	-50.0	20.0	215.0	338.0	654.0	255.0	0.0	6818.0
10	1364.0	857.0	2983.0	123.0	0.0	-38.0	31.0	180.0	392.0	638.0	-3.0	0.0	6527.0
11	1350.0	841.0	2955.0	125.0	0.0	-20.0	46.0	146.0	367.0	607.0	-7.0	0.0	6410.0
12	1397.0	877.0	3022.0	125.0	0.0	-37.0	32.0	160.0	370.0	596.0	-83.0	0.0	6459.0
13	1484.0	921.0	3263.0	122.0	0.0	8.0	76.0	143.0	355.0	534.0	-260.0	0.0	6646.0
14	1417.0	882.0	3155.0	119.0	0.0	19.0	82.0	162.0	335.0	485.0	-322.0	0.0	6334.0
15	1358.0	865.0	3025.0	125.0	0.0	-19.0	48.0	168.0	376.0	608.0	-30.0	0.0	6524.0
16	1303.0	840.0	2996.0	122.0	0.0	-14.0	52.0	151.0	361.0	595.0	17.0	0.0	6423.0
17	1343.0	862.0	3033.0	128.0	0.0	-13.0	52.0	155.0	373.0	609.0	-12.0	0.0	6530.0
18	1380.0	869.0	2988.0	130.0	0.0	-45.0	29.0	188.0	405.0	662.0	40.0	0.0	6646.0
19	1380.0	869.0	3005.0	128.0	0.0	-18.0	48.0	146.0	354.0	579.0	4.0	0.0	6495.0
20	1513.0	940.0	3320.0	130.0	0.0	-4.0	60.0	197.0	371.0	552.0	-315.0	0.0	6764.0
21	1502.0	938.0	3325.0	130.0	0.0	13.0	78.0	189.0	353.0	537.0	-318.0	0.0	6747.0
22	1422.0	898.0	3085.0	135.0	0.0	-12.0	51.0	161.0	385.0	653.0	55.0	0.0	6833.0
23	968.0	572.0	2471.0	1547.0	0.0	-61.0	8.0	191.0	393.0	650.0	-23.0	0.0	6716.0
24	653.0	382.0	1569.0	2931.0	0.0	-81.0	-7.0	158.0	379.0	658.0	21.0	0.0	6663.0
25	696.0	412.0	1594.0	2965.0	0.0	-88.0	-15.0	187.0	382.0	649.0	-40.0	0.0	6742.0
26	616.0	360.0	1525.0	2853.0	0.0	-80.0	-3.0	179.0	357.0	579.0	-88.0	0.0	6298.0
27	617.0	368.0	1682.0	3116.0	0.0	-47.0	23.0	201.0	323.0	477.0	-327.0	0.0	6433.0
28	636.0	364.0	1632.0	3010.0	0.0	-40.0	32.0	194.0	346.0	497.0	-414.0	0.0	6257.0
29	645.0	376.0	1554.0	2905.0	0.0	-63.0	13.0	184.0	385.0	628.0	-85.0	0.0	6542.0
30	655.0	402.0	1551.0	2884.0	0.0	-24.0	49.0	166.0	386.0	624.0	-61.0	0.0	6632.0
31	619.0	368.0	1541.0	2879.0	0.0	-59.0	16.0	187.0	389.0	622.0	-108.0	0.0	6454.0
Monthly T...	37124.00	23139.00	82984.00	27809.00	0.00	-1012.00	1146.00	5488.00	11575.00	18770.00	-1857.00	0.00	205166.00



Monthly Report
Meter Chamber
Net Flow Totals

Town of Tecumseh
Water System
Reports
M_FlowTotal_Net_MCx
01/05/2021 03:26:00 AM

Report Date From: 01/04/2021 12:00:00 AM
To: 01/05/2021 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	611.0	361.0	1496.0	2805.0	0.0	-62.0	13.0	177.0	376.0	604.0	-92.0	0.0	6289.0
2	661.0	374.0	1625.0	3030.0	0.0	-33.0	40.0	172.0	348.0	517.0	-352.0	0.0	6382.0
3	633.0	354.0	1620.0	3035.0	0.0	-29.0	40.0	181.0	346.0	502.0	-369.0	0.0	6313.0
4	698.0	390.0	1672.0	3142.0	0.0	-48.0	18.0	182.0	372.0	530.0	-403.0	0.0	6553.0
5	619.0	357.0	1553.0	2930.0	0.0	-50.0	20.0	187.0	376.0	604.0	-197.0	0.0	6399.0
6	692.0	408.0	1644.0	3093.0	0.0	-69.0	4.0	222.0	419.0	683.0	-149.0	0.0	6947.0
7	749.0	444.0	1703.0	3148.0	0.0	-49.0	21.0	201.0	414.0	676.0	-133.0	0.0	7174.0
8	753.0	437.0	1677.0	3085.0	0.0	-52.0	24.0	175.0	405.0	674.0	-69.0	0.0	7109.0
9	723.0	427.0	1651.0	3072.0	0.0	-45.0	28.0	173.0	378.0	621.0	-175.0	0.0	6853.0
10	864.0	493.0	1897.0	3459.0	0.0	-20.0	50.0	195.0	373.0	551.0	-410.0	0.0	7452.0
11	769.0	431.0	1753.0	3215.0	0.0	-25.0	53.0	159.0	329.0	479.0	-393.0	0.0	6770.0
12	765.0	438.0	1606.0	2954.0	0.0	-34.0	42.0	175.0	385.0	637.0	-92.0	0.0	6876.0
13	776.0	452.0	1704.0	3156.0	0.0	-51.0	29.0	186.0	396.0	660.0	-112.0	0.0	7196.0
14	699.0	414.0	1625.0	3042.0	0.0	-62.0	14.0	198.0	395.0	657.0	-86.0	0.0	6896.0
15	697.0	421.0	1624.0	3024.0	0.0	-55.0	25.0	187.0	382.0	633.0	-128.0	0.0	6810.0
16	755.0	454.0	1687.0	3112.0	0.0	-36.0	40.0	165.0	355.0	592.0	-126.0	0.0	6998.0
17	875.0	504.0	1901.0	3495.0	0.0	-11.0	59.0	186.0	351.0	512.0	-387.0	0.0	7485.0
18	859.0	489.0	1881.0	3433.0	0.0	-12.0	58.0	181.0	359.0	528.0	-426.0	0.0	7350.0
19	779.0	455.0	1723.0	3175.0	0.0	-47.0	30.0	187.0	399.0	668.0	-84.0	0.0	7285.0
20	704.0	420.0	1618.0	2944.0	0.0	-41.0	38.0	167.0	383.0	638.0	-84.0	0.0	6787.0
21	670.0	422.0	1678.0	3027.0	0.0	-32.0	40.0	171.0	383.0	632.0	-115.0	0.0	6876.0
22	694.0	433.0	1706.0	3120.0	0.0	-44.0	33.0	177.0	391.0	639.0	-126.0	0.0	7023.0
23	774.0	497.0	1819.0	3301.0	0.0	-41.0	36.0	170.0	383.0	625.0	-121.0	0.0	7443.0
24	867.0	503.0	1931.0	3523.0	0.0	-21.0	37.0	182.0	368.0	539.0	-320.0	0.0	7609.0
25	885.0	516.0	1955.0	3523.0	0.0	2.0	59.0	161.0	347.0	509.0	-333.0	0.0	7624.0
26	871.0	516.0	1839.0	3371.0	0.0	-36.0	24.0	209.0	421.0	687.0	-104.0	0.0	7798.0
27	962.0	544.0	1940.0	3558.0	0.0	-33.0	21.0	221.0	462.0	756.0	-74.0	0.0	8357.0
28	901.0	524.0	1840.0	3370.0	0.0	-41.0	13.0	193.0	445.0	724.0	-119.0	0.0	7850.0
29	773.0	469.0	1700.0	3127.0	0.0	-50.0	-3.0	206.0	392.0	624.0	-139.0	0.0	7099.0
30	839.0	509.0	1792.0	3283.0	0.0	-39.0	14.0	178.0	383.0	624.0	-160.0	0.0	7423.0
Monthly T...	22917.00	13456.00	51860.00	95552.00	0.00	-1166.00	920.00	5524.00	11516.00	18325.00	-5878.00	0.00	213026.00



Monthly Report
Meter Chamber
Net Flow Totals

Town of Tecumseh
Water System
Reports
M_FlowTotal_Net_MCx
01/06/2021 03:26:00 AM

Report Date From: 01/05/2021 12:00:00 AM
To: 01/06/2021 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	946.0	542.0	2005.0	3665.0	0.0	-8.0	66.0	190.0	377.0	569.0	-351.0	0.0	8001.0
2	1095.0	638.0	2208.0	4021.0	0.0	-3.0	37.0	204.0	416.0	591.0	-497.0	0.0	8710.0
3	773.0	464.0	1726.0	3169.0	0.0	-42.0	-11.0	178.0	395.0	625.0	-158.0	0.0	7119.0
4	839.0	503.0	1792.0	3302.0	0.0	-46.0	-16.0	201.0	439.0	714.0	-89.0	0.0	7639.0
5	846.0	509.0	1793.0	3283.0	0.0	-37.0	-7.0	204.0	414.0	676.0	-164.0	0.0	7517.0
6	828.0	484.0	1775.0	3238.0	0.0	-36.0	15.0	210.0	414.0	694.0	-73.0	0.0	7549.0
7	773.0	445.0	1756.0	3283.0	0.0	-71.0	94.0	225.0	418.0	695.0	-142.0	0.0	7476.0
8	863.0	490.0	1934.0	3550.0	0.0	-8.0	56.0	194.0	366.0	561.0	-326.0	0.0	7680.0
9	751.0	444.0	1775.0	3265.0	0.0	-26.0	41.0	192.0	346.0	505.0	-421.0	0.0	6872.0
10	766.0	462.0	1742.0	3240.0	0.0	-37.0	38.0	184.0	394.0	663.0	-57.0	0.0	7395.0
11	825.0	501.0	1801.0	3375.0	0.0	-30.0	39.0	198.0	414.0	679.0	-111.0	0.0	7691.0
12	929.0	551.0	1948.0	3617.0	0.0	-21.0	34.0	211.0	441.0	728.0	-93.0	0.0	8345.0
13	1017.0	589.0	2028.0	3781.0	0.0	-5.0	23.0	200.0	457.0	753.0	-62.0	0.0	8781.0
14	1055.0	682.0	2205.0	4126.0	0.0	-19.0	15.0	293.0	503.0	817.0	-198.0	0.0	9479.0
15	1226.0	852.0	2689.0	4905.0	0.0	39.0	65.0	312.0	493.0	747.0	-490.0	0.0	10838.0
16	760.0	687.0	2368.0	4425.0	0.0	7.0	32.0	312.0	475.0	691.0	-564.0	0.0	9193.0
17	218.0	718.0	2441.0	4579.0	0.0	40.0	60.0	285.0	512.0	857.0	-184.0	0.0	9526.0
18	397.0	813.0	2676.0	4938.0	0.0	23.0	53.0	344.0	599.0	992.0	-181.0	0.0	10654.0
19	555.0	906.0	2863.0	5311.0	0.0	13.0	18.0	346.0	627.0	1016.0	-202.0	0.0	11453.0
20	1824.0	1038.0	3207.0	5885.0	0.0	28.0	32.0	379.0	661.0	1066.0	-264.0	0.0	13856.0
21	893.0	953.0	3184.0	5972.0	0.0	49.0	61.0	405.0	649.0	1074.0	-265.0	0.0	12975.0
22	1670.0	943.0	3132.0	5932.0	0.0	33.0	44.0	409.0	641.0	896.0	-608.0	0.0	13092.0
23	1442.0	823.0	2787.0	5212.0	0.0	33.0	46.0	339.0	537.0	750.0	-460.0	0.0	11509.0
24	1226.0	656.0	2551.0	4827.0	0.0	24.0	14.0	346.0	539.0	774.0	-367.0	0.0	10590.0
25	1207.0	684.0	2591.0	4872.0	0.0	-19.0	-4.0	337.0	603.0	954.0	-129.0	0.0	11096.0
26	1030.0	536.0	2201.0	4094.0	0.0	-11.0	23.0	241.0	482.0	764.0	-118.0	0.0	9242.0
27	975.0	563.0	2058.0	3891.0	0.0	-16.0	13.0	273.0	497.0	828.0	-70.0	0.0	9012.0
28	782.0	468.0	1855.0	3521.0	0.0	-20.0	15.0	235.0	421.0	692.0	-179.0	0.0	7790.0
29	1063.0	642.0	2162.0	4112.0	0.0	-29.0	12.0	266.0	404.0	600.0	-339.0	0.0	8893.0
30	1299.0	754.0	2578.0	4763.0	0.0	-19.0	31.0	326.0	480.0	679.0	-566.0	0.0	10325.0
31	1190.0	696.0	2408.0	4545.0	0.0	-27.0	-19.0	323.0	559.0	912.0	-135.0	0.0	10452.0
Monthly T...	30063.00	20036.00	70239.00	130699.00	0.00	-241.00	920.00	8362.00	14973.00	23562.00	-7863.00	0.00	290750.00



Monthly Report
Meter Chamber
Net Flow Totals

Town of Tecumseh
Water System
Reports
M_FlowTotal_Net_MCx
01/07/2021 03:26:00 AM

Report Date From: 01/06/2021 12:00:00 AM
To: 01/07/2021 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1332.0	641.0	2595.0	4871.0	0.0	-26.0	2.0	353.0	583.0	936.0	-175.0	0.0	11112.0
2	1217.0	614.0	2321.0	4261.0	0.0	-39.0	-11.0	289.0	529.0	885.0	-155.0	0.0	9911.0
3	946.0	545.0	2104.0	3955.0	0.0	-48.0	-11.0	283.0	506.0	828.0	-143.0	0.0	8965.0
4	1061.0	606.0	2345.0	4462.0	0.0	-27.0	0.0	329.0	582.0	948.0	-182.0	0.0	10124.0
5	1410.0	785.0	2880.0	5427.0	0.0	29.0	62.0	394.0	622.0	902.0	-600.0	0.0	11911.0
6	1396.0	726.0	2970.0	5586.0	0.0	29.0	57.0	402.0	630.0	894.0	-609.0	0.0	12081.0
7	1212.0	657.0	2537.0	4832.0	0.0	-41.0	-2.0	373.0	666.0	1114.0	-306.0	0.0	11042.0
8	1283.0	699.0	2401.0	4529.0	0.0	-63.0	-34.0	353.0	598.0	971.0	-292.0	0.0	10445.0
9	1533.0	810.0	2616.0	5026.0	0.0	-33.0	12.0	335.0	607.0	957.0	-39.0	0.0	11824.0
10	1550.0	841.0	2745.0	5282.0	0.0	4.0	19.0	354.0	621.0	924.0	-41.0	0.0	12299.0
11	1644.0	853.0	2955.0	5684.0	0.0	-17.0	2.0	402.0	639.0	921.0	-85.0	0.0	12998.0
12	1670.0	892.0	2995.0	5760.0	0.0	33.0	41.0	362.0	567.0	730.0	-100.0	0.0	12950.0
13	1574.0	800.0	2918.0	5547.0	0.0	-7.0	4.0	364.0	523.0	557.0	-145.0	0.0	12135.0
14	1340.0	727.0	2530.0	4779.0	0.0	-26.0	-27.0	333.0	544.0	800.0	-70.0	0.0	10930.0
15	1396.0	744.0	2648.0	4975.0	0.0	-16.0	6.0	345.0	571.0	879.0	-68.0	0.0	11480.0
16	1733.0	1014.0	3080.0	5756.0	0.0	-19.0	13.0	456.0	691.0	1017.0	-100.0	0.0	13641.0
17	1905.0	1100.0	3191.0	5917.0	0.0	5.0	32.0	444.0	675.0	974.0	-87.0	0.0	14156.0
18	1391.0	787.0	2538.0	4648.0	0.0	-3.0	23.0	272.0	493.0	785.0	-27.0	0.0	10907.0
19	1363.0	803.0	2565.0	4689.0	0.0	11.0	26.0	235.0	402.0	550.0	-65.0	0.0	10579.0
20	1544.0	858.0	2709.0	5226.0	0.0	29.0	65.0	255.0	419.0	484.0	-97.0	0.0	11492.0
21	1213.0	690.0	2335.0	4250.0	0.0	-11.0	41.0	241.0	474.0	779.0	-8.0	0.0	10004.0
22	1307.0	726.0	2424.0	4324.0	0.0	1.0	36.0	286.0	515.0	882.0	1.0	0.0	10502.0
23	1421.0	865.0	2573.0	4628.0	0.0	5.0	39.0	291.0	497.0	802.0	-37.0	0.0	11084.0
24	1267.0	742.0	1921.0	4529.0	0.0	-9.0	29.0	328.0	538.0	849.0	-27.0	0.0	10167.0
25	984.0	553.0	1886.0	3891.0	0.0	-30.0	10.0	237.0	455.0	727.0	-18.0	0.0	8695.0
26	954.0	584.0	2095.0	3926.0	0.0	-16.0	18.0	216.0	385.0	534.0	-41.0	0.0	8655.0
27	1037.0	563.0	2044.0	4103.0	0.0	-48.0	-8.0	243.0	406.0	511.0	-68.0	0.0	8783.0
28	1313.0	742.0	2462.0	4591.0	0.0	-48.0	-18.0	305.0	548.0	878.0	7.0	0.0	10780.0
29	1460.0	828.0	2517.0	4625.0	0.0	-37.0	3.0	266.0	582.0	992.0	36.0	0.0	11272.0
30	1011.0	655.0	2309.0	3647.0	0.0	-33.0	4.0	240.0	508.0	807.0	-9.0	0.0	9139.0
Monthly T...	40467.00	22450.00	76209.00	143726.00	0.00	-451.00	433.00	9586.00	16376.00	24817.00	-3550.00	0.00	330063.00



Monthly Report
Meter Chamber
Net Flow Totals

Town of Tecumseh
Water System
Reports
M_FlowTotal_Net_MCx
01/08/2021 03:26:00 AM

Report Date From: 01/07/2021 12:00:00 AM
To: 01/08/2021 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	463.0	257.0	2351.0	1698.0	0.0	-16.0	9.0	261.0	466.0	666.0	-41.0	0.0	6114.0
2	189.0	222.0	2471.0	2428.0	0.0	-14.0	14.0	237.0	422.0	530.0	-82.0	0.0	6417.0
3	1444.0	715.0	2748.0	4418.0	0.0	-9.0	29.0	305.0	465.0	532.0	-89.0	0.0	10558.0
4	1328.0	789.0	3025.0	4994.0	0.0	28.0	73.0	338.0	505.0	533.0	-109.0	0.0	11504.0
5	707.0	995.0	1346.0	5721.0	0.0	-18.0	-3.0	60.0	722.0	1100.0	-17.0	0.0	10613.0
6	0.0	816.0	1251.0	4875.0	0.0	-103.0	-79.0	-314.0	800.0	1374.0	59.0	0.0	8679.0
7	0.0	725.0	2330.0	4359.0	0.0	-109.0	-69.0	-87.0	695.0	1182.0	24.0	0.0	9050.0
8	1010.0	625.0	2043.0	3841.0	0.0	-107.0	-68.0	286.0	500.0	758.0	-37.0	0.0	8851.0
9	1081.0	682.0	2227.0	4140.0	0.0	-65.0	-54.0	294.0	527.0	841.0	-18.0	0.0	9655.0
10	1182.0	725.0	2408.0	4459.0	0.0	-57.0	-28.0	314.0	458.0	564.0	-116.0	0.0	9909.0
11	1009.0	580.0	2166.0	3944.0	0.0	-53.0	-23.0	236.0	362.0	426.0	-102.0	0.0	8545.0
12	946.0	586.0	2095.0	3833.0	0.0	-34.0	-4.0	215.0	479.0	806.0	-1.0	0.0	8921.0
13	1140.0	674.0	2152.0	3922.0	0.0	-79.0	-41.0	249.0	497.0	819.0	2.0	0.0	9335.0
14	974.0	599.0	2061.0	3924.0	0.0	-62.0	-27.0	256.0	523.0	877.0	21.0	0.0	9146.0
15	1132.0	688.0	2189.0	4074.0	0.0	-61.0	-23.0	276.0	544.0	889.0	7.0	0.0	9715.0
16	1134.0	675.0	2186.0	3978.0	0.0	-39.0	-7.0	217.0	429.0	652.0	-24.0	0.0	9201.0
17	1075.0	652.0	2184.0	4035.0	0.0	-3.0	28.0	147.0	356.0	491.0	-46.0	0.0	8919.0
18	1153.0	653.0	2329.0	4268.0	0.0	-23.0	15.0	209.0	374.0	408.0	-84.0	0.0	9302.0
19	1064.0	601.0	2251.0	4186.0	0.0	-48.0	-21.0	275.0	492.0	802.0	-10.0	0.0	9592.0
20	1207.0	693.0	2314.0	4265.0	0.0	-55.0	-23.0	290.0	517.0	783.0	0.0	0.0	9991.0
21	1052.0	662.0	2210.0	4128.0	0.0	-39.0	-6.0	281.0	539.0	893.0	0.0	0.0	9720.0
22	1247.0	758.0	2377.0	4388.0	0.0	-27.0	7.0	301.0	553.0	857.0	0.0	0.0	10461.0
23	1616.0	921.0	2614.0	4654.0	0.0	-20.0	28.0	224.0	480.0	776.0	0.0	0.0	11293.0
24	1288.0	800.0	2516.0	4552.0	0.0	6.0	50.0	173.0	385.0	541.0	0.0	0.0	10311.0
25	1015.0	665.0	2391.0	4339.0	0.0	17.0	60.0	143.0	364.0	497.0	0.0	0.0	9491.0
26	1044.0	568.0	2220.0	4183.0	0.0	-49.0	-18.0	262.0	540.0	859.0	0.0	0.0	9609.0
27	1200.0	677.0	2341.0	4330.0	0.0	-42.0	-6.0	285.0	558.0	907.0	0.0	0.0	10250.0
28	1590.0	982.0	2736.0	4990.0	0.0	-34.0	4.0	326.0	577.0	912.0	0.0	0.0	12083.0
29	1469.0	904.0	2561.0	4659.0	0.0	-14.0	14.0	288.0	526.0	830.0	5.0	0.0	11242.0
30	1382.0	847.0	2524.0	4614.0	0.0	-44.0	-16.0	305.0	524.0	785.0	-37.0	0.0	10884.0
31	1436.0	892.0	2659.0	4906.0	0.0	3.0	26.0	301.0	435.0	569.0	-86.0	0.0	11141.0
Monthly T...	32577.00	21628.00	71276.00	131105.00	0.00	-1170.00	-159.00	6953.00	15614.00	23459.00	-781.00	0.00	300502.00



Monthly Report
Meter Chamber
Net Flow Totals

Town of Tecumseh
Water System
Reports
M_FlowTotal_Net_MCx
01/09/2021 03:26:00 AM

Report Date From: 01/08/2021 12:00:00 AM
To: 01/09/2021 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1291.0	756.0	2479.0	4569.0	0.0	-15.0	23.0	229.0	397.0	501.0	-91.0	0.0	10139.0
2	1376.0	786.0	2643.0	4950.0	0.0	-6.0	26.0	272.0	495.0	681.0	-104.0	0.0	11119.0
3	1113.0	616.0	2332.0	4472.0	0.0	-46.0	-16.0	336.0	574.0	903.0	-11.0	0.0	10273.0
4	1239.0	742.0	2520.0	4874.0	0.0	-54.0	-16.0	367.0	616.0	954.0	-20.0	0.0	11222.0
5	1418.0	836.0	2661.0	5108.0	0.0	-65.0	-27.0	385.0	631.0	926.0	-54.0	0.0	11819.0
6	1656.0	935.0	2957.0	5531.0	0.0	-14.0	25.0	375.0	644.0	972.0	-50.0	0.0	13031.0
7	1832.0	1078.0	3120.0	5792.0	0.0	-5.0	8.0	341.0	549.0	718.0	-108.0	0.0	13325.0
8	1612.0	911.0	2882.0	5377.0	0.0	-57.0	-27.0	340.0	489.0	529.0	-165.0	0.0	11891.0
9	1563.0	910.0	2701.0	5036.0	0.0	-88.0	-53.0	392.0	660.0	1051.0	-45.0	0.0	12127.0
10	1518.0	897.0	2621.0	4842.0	0.0	-48.0	-11.0	330.0	640.0	1072.0	30.0	0.0	11891.0
11	1553.0	975.0	2648.0	4894.0	0.0	-102.0	-69.0	307.0	616.0	1000.0	3.0	0.0	11825.0
12	1424.0	894.0	2419.0	4390.0	0.0	-48.0	-16.0	239.0	528.0	855.0	-21.0	0.0	10664.0
13	1473.0	884.0	2565.0	4663.0	0.0	-57.0	-21.0	303.0	572.0	934.0	-16.0	0.0	11300.0
14	1486.0	911.0	2646.0	4782.0	0.0	3.0	37.0	242.0	398.0	525.0	-63.0	0.0	10967.0
15	1541.0	907.0	2770.0	4986.0	0.0	28.0	72.0	235.0	398.0	509.0	-78.0	0.0	11368.0
16	1581.0	979.0	2649.0	4704.0	0.0	-37.0	-3.0	289.0	570.0	911.0	-7.0	0.0	11636.0
17	1611.0	973.0	2709.0	4831.0	0.0	-4.0	25.0	287.0	557.0	965.0	13.0	0.0	11967.0
18	1765.0	1102.0	2893.0	5171.0	0.0	-37.0	3.0	337.0	601.0	961.0	-30.0	0.0	12766.0
19	1844.0	1136.0	3035.0	5465.0	0.0	-26.0	-1.0	364.0	615.0	944.0	-59.0	0.0	13317.0
20	1944.0	1145.0	3243.0	5863.0	0.0	-10.0	13.0	399.0	682.0	1091.0	-74.0	0.0	14296.0
21	2198.0	1334.0	3485.0	6262.0	0.0	17.0	54.0	343.0	521.0	690.0	-151.0	0.0	14753.0
22	2063.0	1191.0	3434.0	6160.0	0.0	44.0	83.0	328.0	493.0	611.0	-111.0	0.0	14296.0
23	2090.0	1262.0	3384.0	6127.0	0.0	-5.0	-6.0	398.0	690.0	1073.0	-80.0	0.0	14933.0
24	2202.0	1289.0	3442.0	6230.0	0.0	-48.0	-32.0	385.0	660.0	1001.0	-83.0	0.0	15046.0
25	2044.0	1265.0	3256.0	5772.0	0.0	-23.0	6.0	317.0	581.0	937.0	-41.0	0.0	14114.0
26	2083.0	1288.0	3285.0	5828.0	0.0	3.0	36.0	259.0	298.0	935.0	-4.0	0.0	14011.0
27	2144.0	1299.0	3305.0	5898.0	0.0	17.0	51.0	269.0	0.0	882.0	-19.0	0.0	13846.0
28	1971.0	1250.0	3287.0	5956.0	0.0	62.0	77.0	257.0	0.0	676.0	-67.0	0.0	13469.0
29	2180.0	1320.0	3463.0	6214.0	0.0	40.0	59.0	280.0	0.0	534.0	-150.0	0.0	13940.0
30	1793.0	1127.0	2906.0	5228.0	0.0	-10.0	11.0	280.0	0.0	907.0	-6.0	0.0	12236.0
31	1886.0	1130.0	3044.0	5460.0	0.0	20.0	32.0	269.0	0.0	895.0	-29.0	0.0	12707.0
Monthly T...	53494.00	32128.00	90784.00	165435.00	0.00	-571.00	343.00	9754.00	14475.00	26143.00	-1691.00	0.00	390294.00



Monthly Report
Meter Chamber
Net Flow Totals

Town of Tecumseh
Water System
Reports
M_FlowTotal_Net_MCx
01/10/2021 03:26:00 AM

Report Date From: 01/09/2021 12:00:00 AM

To: 01/10/2021 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	2003.0	1250.0	3147.0	5651.0	0.0	8.0	23.0	343.0	302.0	927.0	-72.0	0.0	13582.0
2	2068.0	1272.0	3241.0	5870.0	0.0	35.0	45.0	315.0	581.0	917.0	-44.0	0.0	14300.0
3	2158.0	1311.0	3379.0	6065.0	0.0	56.0	69.0	330.0	593.0	960.0	-52.0	0.0	14869.0
4	2099.0	1295.0	3289.0	5922.0	0.0	37.0	59.0	301.0	482.0	622.0	-132.0	0.0	13974.0
5	2008.0	1240.0	3188.0	5647.0	0.0	56.0	75.0	217.0	393.0	524.0	-95.0	0.0	13253.0
6	2252.0	1385.0	3546.0	6199.0	0.0	69.0	110.0	284.0	312.0	553.0	-140.0	0.0	14570.0
7	2002.0	1218.0	3103.0	5414.0	0.0	39.0	69.0	263.0	0.0	883.0	-18.0	0.0	12973.0
8	1865.0	1183.0	2895.0	5041.0	0.0	5.0	36.0	243.0	0.0	840.0	-10.0	0.0	12098.0
9	1905.0	1194.0	2968.0	5183.0	0.0	15.0	40.0	250.0	0.0	777.0	-42.0	0.0	12290.0
10	2093.0	1272.0	3217.0	5629.0	0.0	22.0	43.0	306.0	208.0	784.0	-87.0	0.0	13487.0
11	2146.0	1334.0	3335.0	5864.0	0.0	52.0	79.0	273.0	442.0	584.0	-106.0	0.0	14003.0
12	2183.0	1330.0	3438.0	6032.0	0.0	67.0	97.0	254.0	415.0	498.0	-117.0	0.0	14197.0
13	2008.0	1263.0	3099.0	5419.0	0.0	26.0	54.0	286.0	538.0	876.0	-34.0	0.0	13535.0
14	1973.0	1206.0	2740.0	5424.0	0.0	22.0	55.0	292.0	570.0	919.0	-17.0	0.0	13184.0
15	1884.0	1200.0	2918.0	5039.0	0.0	39.0	64.0	226.0	507.0	857.0	7.0	0.0	12741.0
16	1842.0	1144.0	2924.0	5126.0	0.0	30.0	60.0	275.0	509.0	815.0	-29.0	0.0	12696.0
17	1993.0	1220.0	3156.0	5556.0	0.0	33.0	61.0	284.0	564.0	930.0	-13.0	0.0	13784.0
18	2042.0	1284.0	3256.0	5781.0	0.0	51.0	75.0	282.0	457.0	617.0	0.0	0.0	13845.0
19	2127.0	1297.0	3366.0	5945.0	0.0	68.0	105.0	288.0	464.0	615.0	0.0	0.0	14275.0
20	1845.0	1163.0	2929.0	5138.0	0.0	32.0	53.0	263.0	539.0	917.0	1.0	0.0	12880.0
21	1704.0	1038.0	1019.0	4685.0	0.0	24.0	51.0	240.0	502.0	848.0	-32.0	0.0	10079.0
22	1598.0	1022.0	1580.0	4520.0	0.0	29.0	59.0	228.0	449.0	741.0	-18.0	0.0	10208.0
23	1559.0	979.0	2558.0	4616.0	0.0	31.0	61.0	219.0	437.0	699.0	-28.0	0.0	11131.0
24	1572.0	975.0	2575.0	4486.0	0.0	14.0	50.0	198.0	429.0	736.0	-2.0	0.0	11033.0
25	1625.0	1015.0	2635.0	4562.0	0.0	18.0	50.0	168.0	367.0	562.0	-39.0	0.0	10963.0
26	1673.0	1000.0	2760.0	4750.0	0.0	12.0	50.0	177.0	338.0	426.0	-72.0	0.0	11114.0
27	1537.0	1029.0	2773.0	4891.0	0.0	21.0	55.0	229.0	503.0	899.0	24.0	0.0	11961.0
28	1954.0	1183.0	3103.0	6290.0	0.0	249.0	285.0	189.0	483.0	866.0	29.0	0.0	14631.0
29	1819.0	1147.0	2901.0	5381.0	0.0	73.0	210.0	235.0	502.0	874.0	11.0	0.0	13153.0
30	1776.0	1104.0	2799.0	4857.0	0.0	39.0	63.0	215.0	463.0	753.0	7.0	0.0	12076.0
Monthly T...	57313.00	35553.00	87837.00	160983.00	0.00	1272.00	2206.00	7673.00	12349.00	22819.00	-1120.00	0.00	386885.00



Monthly Report
Meter Chamber
Net Flow Totals

Town of Tecumseh
Water System
Reports

M_FlowTotal_Net_MCx
01/11/2021 03:26:00 AM

Report Date From: 01/10/2021 12:00:00 AM

To: 01/11/2021 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1709.0	1039.0	2796.0	4814.0	0.0	9.0	43.0	225.0	196.0	798.0	-1.0	0.0	11628.0
2	1743.0	1104.0	2862.0	4930.0	0.0	43.0	75.0	148.0	0.0	541.0	-47.0	0.0	11399.0
3	1582.0	967.0	2704.0	4638.0	0.0	5.0	46.0	170.0	0.0	429.0	-86.0	0.0	10455.0
4	1510.0	962.0	2513.0	4328.0	0.0	9.0	44.0	155.0	0.0	755.0	23.0	0.0	10299.0
5	1367.0	848.0	2336.0	4065.0	0.0	-5.0	35.0	156.0	0.0	695.0	6.0	0.0	9503.0
6	1312.0	845.0	2306.0	4055.0	0.0	-10.0	32.0	169.0	0.0	725.0	9.0	0.0	9443.0
7	1330.0	842.0	2318.0	4073.0	0.0	-14.0	31.0	168.0	201.0	701.0	-4.0	0.0	9646.0
8	1397.0	848.0	2394.0	4186.0	0.0	-15.0	33.0	167.0	387.0	611.0	-19.0	0.0	9989.0
9	1365.0	866.0	2471.0	4370.0	0.0	0.0	38.0	153.0	321.0	407.0	-58.0	0.0	9933.0
10	1364.0	862.0	2405.0	4210.0	0.0	11.0	56.0	117.0	273.0	333.0	-66.0	0.0	9565.0
11	1295.0	817.0	2392.0	4232.0	0.0	2.0	50.0	133.0	322.0	404.0	-65.0	0.0	9582.0
12	1175.0	750.0	2153.0	3838.0	0.0	-14.0	30.0	147.0	412.0	692.0	9.0	0.0	9192.0
13	1356.0	873.0	2361.0	4155.0	0.0	-21.0	10.0	201.0	440.0	706.0	-9.0	0.0	10072.0
14	1330.0	852.0	2308.0	4032.0	0.0	-8.0	18.0	154.0	425.0	718.0	18.0	0.0	9847.0
15	1251.0	812.0	2212.0	3873.0	0.0	3.0	32.0	172.0	384.0	629.0	-8.0	0.0	9360.0
16	1113.0	704.0	2143.0	3848.0	0.0	-4.0	26.0	163.0	317.0	441.0	-45.0	0.0	8706.0
17	963.0	614.0	2070.0	3783.0	0.0	1.0	32.0	161.0	300.0	375.0	-68.0	0.0	8231.0
18	1039.0	664.0	2048.0	3496.0	0.0	-30.0	-1.0	205.0	413.0	615.0	-16.0	0.0	8433.0
19	925.0	597.0	1910.0	3467.0	0.0	-29.0	-5.0	190.0	429.0	668.0	-4.0	0.0	8148.0
20	905.0	584.0	1904.0	3449.0	0.0	-21.0	6.0	187.0	426.0	679.0	1.0	0.0	8120.0
21	942.0	602.0	1892.0	3438.0	0.0	-15.0	11.0	176.0	405.0	639.0	-6.0	0.0	8084.0
22	1014.0	657.0	1967.0	3568.0	0.0	-16.0	15.0	182.0	388.0	594.0	-6.0	0.0	8363.0
23	1112.0	693.0	1750.0	3820.0	0.0	14.0	43.0	148.0	294.0	407.0	-36.0	0.0	8245.0
24	1099.0	696.0	0.0	3859.0	0.0	8.0	43.0	155.0	0.0	304.0	0.0	0.0	6164.0
25	1076.0	695.0	2005.0	3624.0	0.0	9.0	38.0	137.0	0.0	548.0	0.0	0.0	8132.0
26	1042.0	667.0	1979.0	3574.0	0.0	-19.0	11.0	175.0	222.0	653.0	0.0	0.0	8304.0
27	1041.0	668.0	1981.0	3583.0	0.0	-22.0	24.0	191.0	411.0	661.0	44.0	0.0	8582.0
28	1042.0	662.0	1972.0	3586.0	0.0	-22.0	46.0	179.0	415.0	680.0	13.0	0.0	8573.0
29	1067.0	675.0	1992.0	3581.0	0.0	-11.0	58.0	155.0	359.0	556.0	-7.0	0.0	8425.0
30	1124.0	706.0	2148.0	3806.0	0.0	7.0	81.0	148.0	309.0	408.0	-41.0	0.0	8696.0
31	1088.0	680.0	2108.0	3750.0	0.0	-1.0	70.0	173.0	287.0	295.0	-82.0	0.0	8368.0
Monthly T...	37678.00	23851.00	66400.00	122031.00	0.00	-156.00	1071.00	5160.00	8336.00	17667.00	-551.00	0.00	281487.00



Monthly Report
Meter Chamber
Net Flow Totals

Town of Tecumseh
Water System
Reports
M_FlowTotal_Net_MCx
01/12/2021 03:26:00 AM

Report Date From: 01/11/2021 12:00:00 AM

To: 01/12/2021 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1024.0	654.0	1979.0	3554.0	0.0	-8.0	66.0	155.0	369.0	600.0	4.0	0.0	8397.0
2	1008.0	638.0	1945.0	3494.0	0.0	-11.0	58.0	174.0	383.0	602.0	-3.0	0.0	8288.0
3	954.0	600.0	1889.0	3418.0	0.0	-22.0	49.0	165.0	375.0	574.0	-7.0	0.0	7995.0
4	990.0	622.0	1910.0	3475.0	0.0	-36.0	44.0	256.0	552.0	945.0	57.0	0.0	8815.0
5	964.0	618.0	1905.0	3469.0	0.0	-20.0	49.0	186.0	361.0	534.0	-15.0	0.0	8051.0
6	1076.0	660.0	2102.0	3734.0	0.0	-8.0	63.0	176.0	300.0	335.0	-75.0	0.0	8363.0
7	1315.0	819.0	2732.0	5047.0	0.0	-156.0	-59.0	404.0	464.0	253.0	-214.0	0.0	10605.0
8	989.0	636.0	1919.0	3400.0	0.0	2.0	78.0	197.0	456.0	745.0	44.0	0.0	8466.0
9	1007.0	640.0	1929.0	3407.0	0.0	-28.0	41.0	184.0	401.0	641.0	2.0	0.0	8224.0
10	1016.0	661.0	1999.0	3481.0	0.0	0.0	62.0	168.0	370.0	564.0	-13.0	0.0	8308.0
11	759.0	493.0	1590.0	2805.0	0.0	-21.0	32.0	145.0	340.0	522.0	0.0	0.0	6665.0
12	959.0	613.0	1908.0	3352.0	0.0	1.0	66.0	168.0	370.0	585.0	-2.0	0.0	8020.0
13	1056.0	662.0	2075.0	3587.0	0.0	16.0	76.0	159.0	283.0	338.0	-72.0	0.0	8180.0
14	1098.0	689.0	2139.0	3692.0	0.0	5.0	72.0	159.0	292.0	310.0	-93.0	0.0	8363.0
15	905.0	576.0	1915.0	3375.0	0.0	-21.0	43.0	158.0	372.0	592.0	-5.0	0.0	7910.0
16	953.0	598.0	1866.0	3323.0	0.0	-37.0	27.0	174.0	375.0	565.0	-21.0	0.0	7823.0
17	938.0	589.0	1858.0	3283.0	0.0	-22.0	42.0	164.0	409.0	664.0	17.0	0.0	7942.0
18	967.0	609.0	1904.0	3371.0	0.0	-24.0	42.0	178.0	398.0	636.0	8.0	0.0	8089.0
19	1038.0	655.0	1966.0	3495.0	0.0	-25.0	50.0	171.0	401.0	645.0	16.0	0.0	8412.0
20	967.0	592.0	1983.0	3498.0	0.0	4.0	69.0	161.0	340.0	492.0	-30.0	0.0	8076.0
21	987.0	604.0	2017.0	3584.0	0.0	-6.0	65.0	173.0	328.0	408.0	-71.0	0.0	8089.0
22	938.0	587.0	1878.0	3359.0	0.0	-27.0	36.0	175.0	420.0	695.0	22.0	0.0	8083.0
23	847.0	561.0	1876.0	3320.0	0.0	-22.0	35.0	189.0	415.0	658.0	7.0	0.0	7886.0
24	927.0	592.0	1901.0	3391.0	0.0	-11.0	52.0	169.0	406.0	674.0	18.0	0.0	8119.0
25	965.0	597.0	1852.0	3336.0	0.0	-46.0	20.0	216.0	426.0	637.0	-2.0	0.0	8001.0
26	955.0	595.0	1850.0	3316.0	0.0	-22.0	40.0	163.0	376.0	603.0	5.0	0.0	7881.0
27	1066.0	650.0	2025.0	3558.0	0.0	8.0	68.0	163.0	322.0	424.0	-53.0	0.0	8231.0
28	1095.0	660.0	2077.0	3652.0	0.0	21.0	80.0	159.0	309.0	397.0	-56.0	0.0	8394.0
29	1088.0	675.0	1994.0	3517.0	0.0	5.0	61.0	166.0	382.0	606.0	10.0	0.0	8504.0
30	1012.0	629.0	1911.0	3390.0	0.0	-5.0	56.0	198.0	409.0	663.0	12.0	0.0	8275.0
Monthly T...	29863.00	18774.00	58894.00	104683.00	0.00	-516.00	1483.00	5473.00	11404.00	16907.00	-510.00	0.00	246455.00



Monthly Report
Meter Chamber
Net Flow Totals

Town of Tecumseh
Water System
Reports
M_FlowTotal_Net_MCx
01/01/2022 03:26:00 AM

Report Date From: 01/12/2021 12:00:00 AM

To: 01/01/2022 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	985.0	613.0	1890.0	3379.0	0.0	-13.0	48.0	220.0	427.0	668.0	6.0	0.0	8223.0
2	1075.0	659.0	1976.0	3506.0	0.0	-35.0	28.0	234.0	432.0	637.0	-5.0	0.0	8507.0
3	999.0	612.0	1880.0	3374.0	0.0	-19.0	45.0	188.0	399.0	653.0	29.0	0.0	8160.0
4	1099.0	681.0	2104.0	3708.0	0.0	-36.0	31.0	193.0	340.0	402.0	-19.0	0.0	8503.0
5	1021.0	614.0	2006.0	3574.0	0.0	-14.0	51.0	208.0	331.0	357.0	-73.0	0.0	8075.0
6	1013.0	622.0	1901.0	3373.0	0.0	-13.0	50.0	175.0	386.0	596.0	8.0	0.0	8111.0
7	1013.0	616.0	1889.0	3372.0	0.0	-29.0	35.0	208.0	400.0	613.0	1.0	0.0	8118.0
8	806.0	491.0	1724.0	3182.0	0.0	-38.0	29.0	191.0	402.0	623.0	11.0	0.0	7421.0
9	813.0	490.0	1688.0	3114.0	0.0	-50.0	18.0	230.0	429.0	672.0	10.0	0.0	7414.0
10	781.0	472.0	1673.0	3097.0	0.0	-41.0	23.0	196.0	389.0	628.0	22.0	0.0	7240.0
11	973.0	573.0	1937.0	3471.0	0.0	-7.0	55.0	162.0	328.0	457.0	-21.0	0.0	7928.0
12	1199.0	727.0	2188.0	3813.0	0.0	7.0	70.0	159.0	294.0	352.0	-57.0	0.0	8752.0
13	1176.0	719.0	2038.0	3593.0	0.0	-18.0	44.0	190.0	396.0	607.0	5.0	0.0	8750.0
14	1050.0	642.0	1912.0	3415.0	0.0	-39.0	24.0	214.0	408.0	649.0	9.0	0.0	8284.0
15	1081.0	668.0	1952.0	3461.0	0.0	-21.0	40.0	189.0	388.0	635.0	12.0	0.0	8405.0
16	1012.0	611.0	1877.0	3358.0	0.0	-28.0	37.0	193.0	402.0	658.0	17.0	0.0	8137.0
17	835.0	506.0	1695.0	3113.0	0.0	-37.0	29.0	192.0	393.0	640.0	22.0	0.0	7388.0
18	776.0	455.0	1729.0	3161.0	0.0	-21.0	44.0	172.0	322.0	460.0	-29.0	0.0	7069.0
19	692.0	461.0	1809.0	3257.0	0.0	2.0	74.0	138.0	283.0	353.0	-49.0	0.0	7020.0
20	745.0	455.0	1655.0	3089.0	0.0	-82.0	-62.0	177.0	384.0	590.0	6.0	0.0	6957.0
21	747.0	456.0	1636.0	3018.0	0.0	-54.0	12.0	195.0	386.0	595.0	1.0	0.0	6992.0
22	674.0	412.0	1614.0	2993.0	0.0	-41.0	27.0	166.0	367.0	588.0	9.0	0.0	6809.0
23	662.0	397.0	1614.0	3023.0	0.0	-31.0	35.0	173.0	362.0	570.0	8.0	0.0	6813.0
24	715.0	408.0	1691.0	3140.0	0.0	-7.0	54.0	152.0	312.0	405.0	-47.0	0.0	6823.0
25	686.0	397.0	1599.0	2969.0	0.0	-10.0	53.0	133.0	286.0	354.0	-52.0	0.0	6415.0
26	713.0	415.0	1627.0	3021.0	0.0	-7.0	56.0	125.0	280.0	357.0	-43.0	0.0	6544.0
27	673.0	396.0	1598.0	2947.0	0.0	-13.0	52.0	137.0	287.0	372.0	-46.0	0.0	6403.0
28	664.0	396.0	1575.0	2911.0	0.0	-23.0	44.0	146.0	323.0	454.0	-26.0	0.0	6464.0
29	612.0	368.0	1530.0	2843.0	0.0	-24.0	41.0	140.0	329.0	469.0	-26.0	0.0	6282.0
30	603.0	358.0	1527.0	2860.0	0.0	-37.0	33.0	143.0	316.0	427.0	-41.0	0.0	6189.0
31	712.0	416.0	1648.0	3048.0	0.0	-21.0	47.0	142.0	286.0	345.0	-55.0	0.0	6568.0
Monthly T...	26605.00	16106.00	55182.00	100183.00	0.00	-800.00	1167.00	5481.00	11067.00	16186.00	-413.00	0.00	230764.00